

CUSTOMER	MALL Energy Inc.
SITE/LOCATION	Longview, Tx
UNIT #	

KW	30	DUTY	Standby
VOLTAGE	120/240	RPM	1800
FUEL	Diesel	HZ	60


GENSET		ENGINE		GENERATOR	
Make	MTU Onsite Energy	Make	John Deer	Make	Marathon
Model #	VER30GJC6DT4	Model #	4024TF	Model #	361NSL1600
Serial #	326725-1-1-1110	Serial #	PE4024R026373	Serial #	710539-0210

Mfg Date	2010
Hours	559
Enclosure	Sound Attenuated
Fuel Tank	210

CONTROL PANEL	Basler PGC2020
BATTERY	Group 31
BATTERY CHARGER	Guest 12V
BLOCK HEATER	Kim Hotstart, Acorn
BLOCK HEATER SIZE	1500 Watt/120V

FILTERS	QTY	PART NUMBER	SPEED CONTROLLER
Oil	1	P550758	ACTUATOR
Fuel, Primary	1	P550914	CIRCUIT BREAKER
Fuel, Secondary			FUEL INJ PUMP
Fuel/Water			STARTER
Air	1	77170	RAD HOSE, UPPER
Air, Secondary			RAD HOSE, LOWER
Belts			

**NOTES** Dims: 110" L x 40" W x 92" H.  
Nice single phase generator with subbase fuel tank. Serviced and loadbank tested.



**onsite energy**

MODEL: VER30GJC6DT4  
 SERIAL: 326725-1-1-1110  
 RATING: STANDBY  
 ENGINE: John Deere 4024TF RCLR  
 RPM: 1800 Hz: 60  
 KW: 30 kVA: 30

VOLTS	AMPS	PHASE	WIRE	PF
120/240	125	1	3/12	1.0

WIRE CONFIG: Double Delta

GENERATOR RISE (°C): 105  
 AMPS/TERM: 125  
 INS. CLASS: H

www.mtu-online.com

UL LISTED